



Certificate of Compliance

This certificate is issued for the following:

Pipe Hanger Components for Automatic Sprinkler Systems Tipp Robust Sprinkler Hangers for 3/4" through 8" Pipe

Model No	Description	Hanger Rod Size, in (mm)	Nominal Pipe Size	
			in	(mm)
Tipp Robust Sprinkler Hanger	Pipe Clamp	3/8 (10)	3/4, 1, 1 1/4, 1 1/2, 2, 2 1/2, 3, 4	(20, 25, 32, 40, 50, 65, 80, 100)
Tipp Robust Sprinkler Hanger	Pipe Clamp	1/2 (12)	5, 6	(125, 150)
Tipp Robust Sprinkler Hanger	Pipe Clamp	3/4 (20)	8	(200)

Prepared for:

Tork Baglanti Elemanlari San. Tic. Ltd. Sti.
Makine Ihtisas Organize Sanayi
Bolgesi Mahallesi 27. Sokak No. 6,A
Dilovasi / Kocaeli, Istanbul, Turkey

FM Approvals Class: 1951 (December 2016)

Approval Identification: PR455635

Approval Granted: May 11, 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D.B. Fuller'.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group

